



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA171627

Certificate Holder: Jiangsu Goodwe Power Supply Technology Co., Ltd.
No. 189, Kun Lun Shan Road,
Suzhou New District, 215163 Suzhou,
Jiangsu
P.R. China

Class Description: Non-Declared
Product Description: AC-Coupled Inverter
Brand Name: GOODWE
Model No.: GW5000S-BP
Markings: Grid Input: 230V~ 50Hz 40A 9.2kVA
Grid/backup output: 230V~ 50Hz 21.7A 5.0kVA
Battery: 48Vdc Lead-acid or Li-ion,
Max charge/discharge: 100/100A
-25°C to 60°C, IP65, Class I

Standard: AS/NZS 4777.2:2015
AS 62040.1.1:2003

Conditions: Nil

Certification Mark: SAA171627 or RCM

Date First Registered: 18 July 2017

Date of Expiry: 18 July 2022


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 18-07-17 171627/1