



Ref. Certif. No.

JPTUV-166695-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Rechargeable Li-ion battery system

Name and address of the applicant

GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District 215011 Suzhou, P.R. China

Name and address of the manufacturer

GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District 215011 Suzhou, P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

GoodWe (GuangDe) Power Supply Technology Co., Ltd
No.8, Dongting Rd., Guangde Economic Development Zone
Anhui, P.R. China

Ratings and principal characteristics

Nominal Voltage:
1) 256.0V, 2) 307.2V, 3) 358.4V
4) 409.6V, 5) 460.8V, 6) 512.0V
7) 563.2V.
Rated Capacity: 100Ah
Nominal Discharge/Charge current: 50Adc

Trademark / Brand (if any)

GOODWE (logo)

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

1) GW25.6-BAT-I-G10 , 2) GW30.7-BAT-I-G10 ,
3) GW35.8-BAT-I-G10 , 4) GW40.9-BAT-I-G10 ,
5) GW46.0-BAT-I-G10 , 6) GW51.2-BAT-I-G10 ,
7) GW56.3-BAT-I-G10

Additional information (if necessary may also be reported on page 2)

Detail information refer to test report CN24UDV7 002
Re-issue of JPTUV-166695 dated 2024-11-19, due to first modification.

A sample of the product was tested and found to be in conformity with

IEC 62619:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

CN24UDV7 002

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland Japan Ltd.
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Mail: info@jpn.tuv.com

Date: 2025-08-04

Signature:

Dean Cao

10/061SMD 2024-12 rke-simplified