

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE** Rechargeable Li-ion battery system Product GoodWe Technologies Co., Ltd. Name and address of the applicant No.90 Zijin Rd., New District 215011 Suzhou, P.R. China GoodWe Technologies Co., Ltd. Name and address of the manufacturer No.90 Zijin Rd., New District 215011 Suzhou, P.R. China GoodWe (GuangDe) Power Supply Technology Co., Ltd Name and address of the factory No.8, Dongting Rd., Guangde Economic Development Zone Note: When more than one factory, please report on page 2 Anhui, P.R. China Nominal Voltage: 1) 256.0V, 2) 307.2V, 3) 358.4V 4) 409.6V, 5) 460.8V, 6) 512.0V Ratings and principal characteristics 7) 563.2V. Rated Capacity: 100Ah Nominal Discharge/Charge current: 50Adc Trademark / Brand (if any) GOODWE (logo) Customer's Testing Facility (CTF) Stage used 1) GW25.6-BAT-I-G10 , 2) GW30.7-BAT-I-G10 , 3) GW35.8-BAT-I-G10 , 4) GW40.9-BAT-I-G10 , Model / Type Ref. 5) GW46.0-BAT-I-G10 , 6) GW51.2-BAT-I-G10 , 7) GW56.3-BAT-I-G10 Detail information refer to test report CN24V9K9 002 Additional information (if necessary may also be Re-issue of JPTUV-166697 dated 2024-11-19, due to reported on page 2) first modification. A sample of the product was tested and found IEC 63056:2020 to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

CN24V9K9 002

This CB Test Certificate is issued by the National Certification Body



2025-08-04

TÜV Rheinland Japan Ltd. 4-25-2 Kita-Yamata, Tsuzuki-ku Yokohama 224-0021, Japan,

Mail: info@jpn.tuv.com

Dean Cao Signature:

Date: